Energy performance certificate (EPC)					
Flat 504 Noble House 48, Ottley Drive LONDON SE3 9GF	Energy rating	Valid until: 19 October 2027 Certificate number: 8823-7630-5229-7450-1926			
Property type	Mid-floor flat				
Total floor area	area 51 square metres				

Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is B. It has the potential to be B.

<u>See how to improve this property's energy</u> performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Walls	Average thermal transmittance 0.2 W/m²K	Very good
Roof	Average thermal transmittance 0.2 W/m²K	Good
Windows	High performance glazing	Very good
Main heating	Community scheme	Good
Main heating control	Charging system linked to use of community heating, programmer and TRVs	Good
Hot water	Community scheme	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Air tightness	Air permeability 3.3 m³/h.m² (as tested)	Good
Floor	(other premises below)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 79 kilowatt hours per square metre (kWh/m2).

Environmental impact of this property		This property produces	0.7 tonnes of CO2
This property's current environmental impact rating is B. It has the potential to be B.		This property's potential production	0.7 tonnes of CO2
Properties are rated in a scale from A to G based on how much carbon dioxide (CO2) they produce.		By making the <u>recommended changes</u> , you could reduce this property's CO2 emissions by 0.0 tonnes per year. This will help to protect the environment.	
Properties with an A rating than G rated properties.	produce less CO2	environment.	
than Grated properties.		Environmental impact ratin assumptions about average	
An average household produces	6 tonnes of CO2	energy use. They may not reflect how energy is consumed by the people living at the property.	

How to improve this property's energy performance

The assessor did not make any recommendations for this property.

<u>Simple Energy Advice has guidance on improving a property's energy use.</u> (<u>https://www.simpleenergyadvice.org.uk/</u>)

Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings		Estimated energy used to heat this property	
potonilai outiligo		Space heating	611 kWh per year
Estimated yearly energy cost for this property	£242		
Potential saving	£0	Water heating	1458 kWh per year
The estimated east shows how much the		Potential energy savings by installing insulation	

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in <u>how to improve this</u> <u>property's energy performance</u>.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u> (<u>https://www.simpleenergyadvice.org.uk/</u>).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive <u>Renewable Heat</u> <u>Incentive payments (https://www.gov.uk/domestic-renewable-heat-incentive)</u>. This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name Telephone Email Simon Gowing 020 3603 1600 <u>lisa@hodkinsonconsultancy.com</u>

Accreditation scheme contact details

Accreditation scheme Assessor ID Telephone Email

Assessment details

Assessor's declaration Date of assessment Date of certificate

Type of assessment

NHER NHER009641 01455 883 250 enquiries@elmhurstenergy.co.uk

No related party 20 October 2017 20 October 2017 SAP